

MITSUBISHI ELECTRIC CORPORATION AIR-CONDITIONING & REFRIGERATION SYSTEMS WORKS

5-66, TEBIRA 6 CHOME, WAKAYAMA-CITY 640-8686, JAPAN PHONE: +81-73-428-9047 FAX: +81-73-428-9002

DECLARATION OF CONFORMITY

(for PED)

We declare that the design manufacturing and inspection of the pressure equipment described following is in conformity with the provisions of annex IV of the Directive 2014/68/EU referred to as the Pressure Equipment Directive.

Name of Manufacturer

: MITSUBISHI ELECTRIC CORPORATION

AIR-CONDITIONING AND REFRIGERATION SYSTEMS WORKS

Address

: 6-5-66 TEBIRA WAKAYAMA-CITY 640-8686, JAPAN

Product name

: AIR CONDITIONER

Model names

: PUHY-P200/250/300/350/400/450YJM-A(-BS),

PUHY-EP200/250/300YJM-A(-BS),

PURY-P200/250/300/350/400/450YJM-A(-BS),

PURY-EP200/250/300/350YJM-A(-BS),

PURY-WP200/250YJM-A(-BS)

Brand name

MITSUBISHI ELECTRIC

Reference of the Directive

2014/68/EU Pressure Equipment Directive

Category & Applied conformity assessment procedure :

Equipment	Category	Conformity Assessment Module	Notified Body ID
Unit Assembly	ll	A2	0035
Accumulator	II	A2	0035
Pressure Switch	II	D1	0035

Nortified body:

TÜV Rheinland Industrie Service GmbH

ID No. 0035

Am Grauen Stein, D-51105 Cologne, Germany

Certification No.: 01 202 J/Ü-16004

Reference of the other Directive:

2004/108/EC

Electromagnetic Compatibility

2006/95/EC

Low Voltage

2006/42/EC

Machinery

2011/65/EU

Restriction of Hazardous Substances

10, Sep, 2010 (date of issue)

Minoru Ogawa Manager

10, Apr. 2017 (date of revision)

Quality Assurance Department